

BEFORE OPERATING ANY GAS EQUIPMENT,
THE EXTRACTION MUST BE ON AND SET TO
POSITION:



THE VENTILATION MUST BE ON AND SET TO
POSITION:



OR WINDOWS OPENED.

IN THE EVENT OF AN EMERGENCY THE
MANUAL GAS ISOLATION VALVE MUST BE
CLOSED OR PUSH THE STOP-BUTTON TO
OPERATE SHUT DOWN.

ALL BURNERS AND PILOT VALVES ON
APPLIANCES MUST BE TURNED OFF PRIOR TO
ATTEMPTING TO RESTORE THE SUPPLY AFTER
SHUT-OFF

This Safe Systems of Work poster & its contents are provided for the minimum continued safe operation of your equipment & for the protection of your staff. see British Standards 6173 & Building Engineering Services Association DW/172